

ROOM DATA SURVEY

Ref : PTM EA FORM

PEJABAT KESELAMATAN PEKERJAAN DAN KELESTARIAN ALAM SEKITAR

Pejabat :	
Bangunan	KOMPLEKS DEWAN KULIAH
Aras	2

Tarikh	4/8/2022
Disediakan oleh	Kamal Idham, Amirul Hakimie, Noor Imran
Disemak oleh	Ir.Dr. AIDA FAZLIANA BINTI ABDUL KADIR

Equipment	Model	Serial No.	Calibration expiry date
Temp/RH meter	UNI-T	UT337	
Illuminance meter	DIGITAL LUX METER	L21330B	
CO2 meter	DIGITAL CO2+TEMP+RH%	77597	

No.	Room No/ Description	Area m²	Illuminance [Lux]				Temp [°C]	RH [%]	CO₂ [ppm]	Lighting			Peralatan Lain			Remarks
			P1	P2	P3	Avg				Type (LED/ fluorescent)	Qty OK	Faulty	Nama Alat	Bil	Kuasa (watt)	
BAHAGIAN PENGURUSAN AKADEMIK																
1	RUANG PEJABAT	145.97	617	742	353	570.6667	23.6	75.2	640	fluorescent	50	1	pc	10		
													fan	1	39W	
													printer	3		
													shredder	1		
2	BILIK MESYUARAT	44.702	514	581	632	576	25.3	69.4	711	LED	15	0	aircond	2		
													tv	1	24W	
3	TIMBALAN PENDAFTAR KANAN	25.132	478	803	641	641	25.3	72.3	632	fluorescent	12	0	aircond	1		
													pc	1		
													printer	1		
4	PANTRY	13.629	190	251	183	208	24.8	70.4	743	fluorescent	2	0	peti sejuk	1	240W	
													microwave	1	270W	
													heater	1	200W	
													rice cooker	1	400W	
													aircond	1		
													toaster	1		
5	BILIK PPT	10.375	230	387	617	411.3333	25.1	65.8	757	fluorescent	2	0	aircond	1		
													DR	1		
6	PENOLONG PENDAFTAR	12.66	182	295	54	177	25.3	65.81	765	fluorescent	2	0	aircond	1		
													DR	1		
7	PEJABAT PEGAWAI TADBIR	12.3136	214	163	221	199.3333	25.6	74	702	fluorescent	2	0	aircond	1		
													DR	1		
8	PEJABAT PEGAWAI TADBIR	12.3136	271	157	691	373	25.6	67.3	720	fluorescent	2	0	aircond	1		
													DR	1		
9	BILIK FAIL	19.03	258	298	198	193.2575	26.1	67.1	600	fluorescent	4	0				
10	BILIK CETAK	18.72	237	187	396	273.3333	26.8	61.8	620	fluorescent	4	0	aircond	1		
													streka	1		

No.	Room No/ Description	Area m²	Illuminance [Lux]				Temp [°C]	RH [%]	CO₂ [ppm]	Lighting			Peralatan Lain			Remarks	
			P1	P2	P3	Avg				Type (LED/ fluorescent)	Qty OK	Faulty	Nama Alat	Bil	Kuasa (watt)		
KAUNTER PERKHIDMATAN PELAJAR																	
1	LOBBY	14.6	231	246	241	239.3333	23.4	72.6	528	fluorescent	3	0	pc	2			
													aircond	1			
2	BILIK PERBINCANGAN	5.094	218	236	224	226	22.7	81.6	628	fluorescent	1	0	aircond	1			