

ROOM DATA SURVEY

Ref : PTM EA FORM

PEJABAT KESELAMATAN PEKERJAAN DAN KELESTARIAN ALAM SEKITAR

Pejabat :	KOMPLEKS DEWAN KULIAH
Bangunan	KOMPLEKS DEWAN KULIAH
Aras	3

Tarikh	4/8/2022
Disediakan oleh	KAMAL,KIMIE,IMRAN
Disemak oleh	Ir.Dr. AIDA FAZLIANA BINTI ABDUL KADIR

Equipment	Model	Serial No.	Calibration expiry date
Temp/RH meter	UNI-T	UT337	
Illuminance meter	DIGITAL LUX METER	L21330B	
CO2 meter	DIGITAL CO2+TEMP+RH%	77597	

No.	Room No/ Description	Area m ²	Illuminance [Lux]				Temp [°C]	RH [%]	CO ₂ [ppm]	Lighting			Peralatan Lain			Remarks
			P1	P2	P3	Avg				Type (LED/fluorescent)	Qty OK	Faulty	Nama Alat	Bil	Kuasa (watt)	
1	DEWAN KULIAH 5	141.01	343	410	350	368	26.4	83.7	560	flueorescent led	3016	0	speaker	2		
													projector	1		
													pa.system	1		
2	DEWAN KULIAH 6	141.01	343	410	350	368	26.4	83.7	560	flueorescent led	3016	0	speaker	2		
													projector	1		
													pa.system	1		
3	DEWAN KULIAH 7	307.768	429	355	384	389	23.9	74.7	509	flueorescent led	6011	0	speaker	6		
													projector	1		
													pa.system	1		
4	DEWAN KULIAH 8	307.768	429	355	384	389	23.9	74.7	509	flueorescent led	6011	0	speaker	6		
													projector	1		
													pa.system	1		
5	LOBBY ARAS 3	112.41	450	160	60	223	23.9	71.3	504	LED	15	1	fan booste	1		